

**REQUEST FOR BID
TRANSFORMER REPLACEMENT
FOR HAWAI'I CONVENTION CENTER**

ITEM NO.	DATE OF QUESTION / RESPONSE	QUESTION / RESPONSE
Q-01	3/17/2023	Can the delivery and installation due date be extended beyond May 31, 2023? Lead times on energy saving, mitigating transformers would dictate that the transformers would not even arrive on island until late August 2023 at the earliest.
		Please provide proposed installation date.
Q-02	3/17/2023	Would HCC like to have install during normal business hours (Monday-Friday, 6am-5pm) or after hours? Requesting clarification as electrical services on the affected electrical panels will be unavailable during the transformer retrofit.
		Regular hour work permitted only on dark days where there is no affect to client usage or after hours. Some events can end late at night so careful scheduling around events is necessary
Q-03	3/17/2023	What parameters does HCC want to collect data from?
		Any data that would apply to the Hawaii Energy rebate. From past expereince we need to prove the new units are energy savings and have a before and after comparison to get applicable rebates. Work with Hi-Engery to determine correct information collection.
Q-04	3/17/2023	What duration would HCC want to perform data logging before and after transformer replacement?
		Please see above comment. Work with Hawai'i Energy to determine what data and what timeframe is applicable to getting the rebates.
Q-05	3/17/2023	Will all four transformers require data collection?
		All transformers will need data collection
Q-06	3/17/2023	Is the sole purpose of the data collection to provide data for Hawai'i Energy rebates? If so, previous transformer projects in our experience have not required any data collection at all tor receive rebate checks from Hawai'i Energy.

		If you can provide proof of non data collection needed in writing from Hawai'i Energy we will accept the bid with no data collection. The other reason to data collect is to determine what savings we are actually getting with the new transformers. This will be for future use in reports
Q-07	3/17/2023	What is the height clearance for the parking garage where contractors are expected to park?
		8'11", larger vehicles may be able to park in loading dock with advanced notice pending event schedules.